



RESULTS SUMMARY REPORT

- UME016/13-

Based in the report CXL082/13

Date: 22/11/2013

Test Owner: GNS – Georgina Neto dos Santos, Lda.

Address: EN1 – Mourisca do Vouga, P.O. Box 3007, 3754-901 Águeda

Contact name: Eng.º Paulo Felizardo

Tel.: +351 234 644 224

e-mail: gns.felizardo@gmail.com

Tested specimen:

It was submitted for testing 1 specimen with the internal reference CXL015A/13, which had the following customer reference: **Horizontal micro-ventilation system Ref. 5250.**

The specimen consisted in a horizontal micro-ventilation system, mounted in a window of aluminum with thermal break, with a tilt-and-turn casement and a turn-only casement.

Performed tests and results:

The test performed to the CXL015A/13 specimen and its results were the following:

Test	Classification
Air permeability test (EN 1026:2000; EN 12207:1999)*	Class 1

* The test was performed with the main casement in micro-ventilation mode.

Note: This report is not a replacement for the individual test reports which served as its basis. For a complete analysis and interpretation of the results see individual test reports.

Report author: Luísa Costa

Technical supervisor: Nuno Simões
(Technical and Scientific Supervisor)

Administration:



UME016/13

This report may not be reproduced, except if complete, without the written consent of ITeCons.